

Environmental Protection Agency
Integrated Compliance Information System
Quarterly Non-compliance Report **QNCR**

Page 1 of 1
From: 07/01/2018 To: 09/30/2018

Major/Minor Indicator(s): Major
NPDES ID(s):
Region(s): 04
State(s): FL
Violation Group(s): DMR, SCH, SEV, EFF
State Region: FMDW

QNCR Year and Quarter: 2018Q4

Florida / Region 04

Location	Grant							
Instance of Noncompliance	RNC	Violation Date	Enforcement Action	Enforcement Date	Status	Status Date	Comments	
POTW								
Facility: ARCADIA CITY OF - WILLIAM TYSON WWTF - NPDES ID: FL0027511 - FRS ID: 110018936552								
ARCADIA	Noncompliant							
DETAIL SECTION								
No linked Enforcement Action or Final Order								
Ammonia, unionized	001-1	TRC	09/30/2018		NC	09/30/2018	3A1 - PERMIT EFF VIO - NON MO AV	
Ammonia, unionized	001-1	TRC	06/30/2018		NC	06/30/2018	3A1 - PERMIT EFF VIO - NON MO AV	
Ammonia, unionized	001-1	TRC	05/31/2018		NC	05/31/2018	3A1 - PERMIT EFF VIO - NON MO AV	
Ammonia, unionized	001-1	TRC	04/30/2018		NC	05/31/2018	3A1 - PERMIT EFF VIO - NON MO AV	

INV: Department Investigating Resolution

Final Comments: Existing CO will be amended to address the ammonia issues. Facility is going to replace the valve/actuator which allows for treated effluent that will not meet reclaimed water standards to automatically reject to the rapid infiltration basins by the end of 12/31/2018. However, before the CO will be amended DEP is awaiting a response on the following questions to finalize the amended CO – 1. Explain how the facility will stop the exceedance for Unionized Ammonia, 2. explain how the facility will know when Unionized Ammonia exceedances exists, and 3. explain how the valves prevent discharges of non-compliant effluent from being discharged to surface water.